



Republic of the Philippines  
Department of Environment and Natural Resources  
**ENVIRONMENTAL MANAGEMENT BUREAU**  
DENR Compound, Visayas Avenue, Diliman, Quezon City 1116  
Tel. Nos.: 927-15-17, 928-37-42  
Email : emb@emb.gov.ph  
Visit us at <http://www.emb.gov.ph>

**SUPPLEMENTAL/BID BULLETIN NO. 1**

**Supply, Delivery, Installation and Commissioning of Lot Structured Cabling system for the Remaining EMB Building**

**ITB No. EMB-GOODS-NCB-2019-0009**

This clarification No. 6435409-1 is issued to clarify/amend item/s in the issued notice posted in PhilGEPS with reference No. 6435409. This Bid Bulletin shall form an integral part of the bid documents

Name of Project : **Supply, Delivery, Installation and Commissioning of Structured Cabling system for the Remaining EMB Building**

Date : September 10, 2019

Announcing the amendments/correction on the issued bidding documents:

<b>Old Technical Specification</b>	<b>New Technical Specification</b>
1 Lot Supply, Delivery, Installation and Commissioning of STRUCTED CABLING SYSTEM FOR ERLSD & OLD EQD BUILDING & SERVER ROOM	
15. For Data Center: Installation of Anti Static vinyl tiles, installation of new glass door & refurbish existing walls. Remove existing window type ACU, Industrial type open ceiling system, installation of Fire Suppression System, EMS & Biometric door access, transfer of all old cables and active equipments from old racks to new Data racks. Retermination of all UTP/FOC, testing/tracing of all UTP/FOC.	15. For Data Center: Installation of Anti Static vinyl tiles, installation of new glass door & refurbish existing walls. Remove existing window type ACU, Industrial type open ceiling system, installation of Fire Suppression System, EMS & Biometric door access, transfer of all old cables and active equipments from old racks to new Data racks. Retermination of all UTP/FOC, testing/tracing of all UTP/FOC. <b>Relocation of existing 3.5HP split type aircon.</b>
<b>Submittals for Qualification:</b>	<b>Submittals for Qualification: SBB</b>
12. Installation Floor Plan Drawing printed in bond paper (signed and sealed).	12. Installation Floor Plan Drawing printed in bond paper (signed and sealed). <b>(to be submitted after project completion)</b>
13. Vendor must conduct Onsite Scoping of the project.	13. <b>Bidder must conduct Onsite Scoping of the project (additional requirement)</b>

For guidance and information of all concerned.

  
**MS. CONSOLACION P. CRISOSTOMO**  
BAC Vice-Chairperson

Received by the Bidder:

Date: \_\_\_\_\_