



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
DENR Compound, Visayas Avenue, Diliman, Quezon City, 1116
Telephone Nos. 927-15-17, 928-50-96
Email: emb@denr.gov.ph
Visit us at <http://www.emb.gov.ph>

SUPPLEMENTAL/BID BULLETIN NO. 1

Supply and Delivery of 4 Units Uninterruptible Power Supply (UPS)

This clarification/addendum No. 6903567-1 is issued to clarify/amend item/s in the issued ITB No. EMB-GOODS-NCB 2020-005. This Bid Bulletin shall form an integral part of the bid documents


Name of Project : **Supply and Delivery of 4 Units Uninterruptible Power Supply (UPS)**

Date : March 16, 2020

Announcing the clarification/amendments/correction on the issued bidding documents:

Old Technical Specifications	New Technical Specifications
<p>UPS: For 3 Units UPS (10 kVA)</p> <ul style="list-style-type: none">o Output bypass selectable for 1,2,3, kVA UPS via LCDo With built-in AVRo Including materials needed for installation	<p>UPS: For 3 Units UPS (10 kVA)</p> <ul style="list-style-type: none">o Removedo Removedo Including materials needed for installation such as circuit breakers for each UPS, 6 220 V outlets (minimum) for GC unit and computer, cables, and insulators <p>Additional Specifications:</p> <ul style="list-style-type: none">o Back-up type: @ full loado Back-up time: at least 5 minuteso Single-phaseo Load Capacity: 5 kVA minimumo Power factor: 0.95 to 1.00o Location: Ground Floor – Organics Laboratory (2 units for two (2) Shimadzu Gas Chromatograph – Electron Capture Detector (GC-ECD) and 1 unit for Thermo Scientific Gas Chromatograph – Mass Spectrometer (GC-MS))
<p>UPS: For 1 Unit UPS (20 kVA)</p> <ul style="list-style-type: none">o With built-in AVRo Including materials needed for installation	<p>UPS: For 1 Unit UPS (20 kVA)</p> <ul style="list-style-type: none">o Removedo Including materials needed for installation such as circuit breakers for each UPS, 4 220 V outlets (minimum) for AAS unit, compressor, cooling unit and computer, cables, and insulators <p>Additional Specifications:</p> <ul style="list-style-type: none">o Back-up type: @ full loado Back-up time: at least 5 minuteso Three-phaseo Load Capacity: 6 kVA minimumo Location: Third Floor – Inorganics Laboratory (for the Graphite Furnace Atomic Absorption Spectrophotometer)

For guidance and information of all concerned.


MS. CONSOLACION P. CRISOSTOMO
BAC Chairperson

Received by the Bidder: _____

Date: _____