



SUPPLEMENTAL/BID BULLETIN NO. 1

Supply of Labor and Materials of the One (1) Lot Installation for the Laboratory Gas Lines Tools

This clarification/addendum No. **7221865-1** is issued to clarify/amend item/s in the issued **ITB No. EMB-GOODS-NCB-2020-0013**. This Bid Bulletin shall form an integral part of the bid documents.

Date : October 13, 2020

Announcing the clarification/amendment/correction on the issued bidding documents:

Old Technical Specifications	New Technical Specifications
Materials: Nailok	Materials: Nailok or equivalent
The bidder's SLCC similar to the contract to be bid should have been completed within Two (2) Years prior to the deadline for the submission and receipt of bids.	The bidder's SLCC similar to the contract to be bid should have been completed within five (5) Years prior to the deadline for the submission and receipt of bids.
Clarification on requirements	Gas filters are not required for fume hoods
Additional requirement	Supplier must provide certification of authenticity of product for stainless steel material SS316 of the gas line components.
	Provide Schematic Design – Gas Delivery Layout of ERLSD Building (Ground Floor-Third Floor)

For guidance and information of all concerned.

ALBERT A. MAGALANG

Chairperson

EMB Bids and Awards Committee

Received by the Bidder:

Date: _____